

Ordinance 159  
Concerning Sidewalks

Be it ordained by the Board of Trustees of the Incorporated Town of Las Animas.

Section 1

There shall be constructed the following sidewalks of a suitable material of a width of eight (8) feet, beginning at Twelfth Street, thence running south on the west side of Carson Avenue to Fourteenth Street; and beginning at Twelfth Street, thence running south on the said side of Carson Avenue to Fourteenth street. Said sidewalks to be constructed of concrete, brick or stone, in accordance with the following specifications.

Concrete Walks

A. All Walks laid with concrete shall be graded sufficiently to a solid surface upon which shall be laid six (6) inches or more of concrete of a mixture of Seven (7) parts gravel to one (1) part or more of cement, which shall be thoroughly mixed and thoroughly tamped, upon which shall be laid a top dressing two parts clean sand to one (1) part of cement of a thickness of one and one fourth ( $1\frac{1}{4}$ ) inches. The curbing to consist of the best quality of sandstone, thoroughly surfaced, with squared edges, not less than Four (4) inches in thickness, or in lieu of said sandstone, concrete curbing thoroughly surfaced may be used, not less than five (5) inches in thickness and not less than twelve (12) inches in depth. The said walk to be surfaced and finished in a thorough and workmanlike manner and to have one (1) inch slope from inside of walk to curbing.

Brick Walk.

B. Brick walks shall consist of the best quality of vitrified paving brick laid upon a bed of sand not less than four (4) inches in thickness. The curbing to consist of the best quality of sandstone, thoroughly surfaced with squared edges, four (4) inches in thickness; or in lieu of said sandstone, concrete curbing, thoroughly surfaced may be used, not less than five (5) inches in thickness and not less than eighteen (18) inches in depth; said walks to have one (1) inch slope from inside of walk to curbing.

Stone Walk.

C. All walks laid of stone shall be not less than four (4) inches in thickness, of the best quality of sandstone dressed to a smooth surface on top with squared joints, and laid in a thorough and workmanship manner; the curbing to consist of good sandstone not less than eighteen (18) inches in depth; or in lieu of said sandstone concrete curbing, thoroughly surfaced. May be used not less than five (5) inches in thickness, and not less than eighteen (18) inches in depth; to be constructed in a thorough and workmanlike manner, and said walk to have a slope of one (1) inch from inside of walk to curbing.

Section 2

All sidewalks hereafter constructed to be laid to a grade furnished by the City Engineer.

Section 3

All street crossings connecting the aforesaid sidewalks, when required to be replaced, shall consist of hard pressed, vitrified brick or concrete, according to such plans and specifications as may be adopted by the Board of Trustees.

Section 4

The construction of all sidewalks and street crossings hereafter to be subject to the supervision and acceptance of the Street Commissioner or an Inspector duly appointed by the Mayor for that purpose.

Section 5

All Ordinances or parts of ordinances in conflict herewith are hereby repealed.

## Section 6

This Ordinance shall take effect five (5) days after its publication in the Las Animas Leader, the official paper of the Town of Las Animas.

NOTE: Passed at a regular meeting of the Board of Trustees of the Incorporated Town of Las Animas, August 15th, AD 1904, a majority of the whole number of members concurring by the following vote; Ayes: John D. Brown, John Bressler, John Gruber, Geo. Powell, and Geo. B. Wick. Nays: None.

ATTEST:

Pearl Walls

Clerk and Recorder.

Frank Kreybill  
Mayor